



EXPLOSION PROTECTION CERTIFICATE OF CONFORMITY

Cert NO.GYB13.1177X

This is to certify that the product

Explosion Proof Valve Return Signaler

manufactured by **Wuxi Aphe Flow Smart Controls Maker Co., Ltd**

(Address:No. 29 Henghua Technical Park, No. 58 Xiuxi Road, Binhu District,
Wuxi, Jiangsu, China)

which model is **ALS-400**

Ex marking **Ex d II C T6 Gb**

product standard **Explosion Proof Valve Return Signaler Factory Standard**

drawing number **ALS400-000**

has been inspected and certified by NEPSI, and that it conforms
to **GB 3836.1-2010,GB 3836.2-2010**

This Approval shall remain in force until **2018.03.26**

Remarks

- 1.Conditions for safe use are specified in the instructions.
- 2.Symbol "X" placed after the certification number denotes specific conditions of use:
1) For information on the dimensions of the flameproof joints contact the manufacturer; 2) Prohibit wiping the plastic surface in order to prevent the dangerous of static.
- 3.The grade of the properties of the fasteners used for the flameproof joint is A2-70.

Director

**National Supervision and Inspection Centre for
Explosion Protection and Safety of Instrumentation**

Issued Date **2013.03.27**

This Certificate is valid for products compatible with the documents and samples approved by NEPSI.

103 Cao Bao Road
Shanghai 200233, China

<http://www.nepsi.org.cn>
Email: info@nepsi.org.cn

Tel: +86 21 64368180
Fax: +86 21 64844580