



# Certificate of Compliance

**Certificate:** 70027180

**Master Contract:** 249178

**Project:** 70027180

**Date Issued:** August 23, 2015

**Issued to:** Wuxi AFL Flow Controls Equipment

E/I Co., Ltd.  
A 4-406 Standard Factory  
Li Yuan Economic  
Developing District  
Wuxi, Jiangsu  
China

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.*



*Roy Chen*

**Issued by:** Roy Chen

## **PRODUCTS**

**CLASS 3211 87** - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus -  
Certified to US Standards

**CLASS 3211 07** - INDUSTRIAL CONTROL EQUIPMENT - Miscellaneous Apparatus

Valve Monitor, enclosed Type 4 and 4X, Models as follows:

ALS-400M2, 2 SPDT, switch type V15T16SZ200A05, max 15 A, 250 V ac;

ALS-400M3, 3 SPDT, switch type V15T16SZ200A05, max 15 A, 250 V ac;

ALS-400M4, 4 SPDT, switch type V15T16SZ200A05, max 15 A, 250 V ac;

ALS-400PA22, switch type ALPS-24, 2 wires, rated 10 - 30 V dc,  $\leq 150\text{mA}$ ;

ALS-400PA23, switch type ALPS-24, 3 wires, rated 10 - 30 V dc,  $\leq 150\text{mA}$ ;

ALS-400QA22, switch type ALMS-5-240, 2 wires, rated 5 - 240 V ac,  $\leq 300\text{mA}$  or 5-24 V dc,  $\leq 100\text{mA}$ ;



**Certificate:** 70027180

**Master Contract:** 249178

**Project:** 70027180

**Date Issued:** August 23, 2015

---

ALS-400PP22, switch type NCB2-V3-No, 2 wires, rated 8 V dc,  $\leq 1$ mA;

ALS-400AS2, switch type AS2, rated 20-28 V dc,  $\leq 4$ mA.

**APPLICABLE REQUIREMENTS**

- CSA C22.2 No. 0-10 - General Requirements
- CSA C22.2 No. 0.4-2004 - Bonding and Grounding of Electrical Equipment
- CSA C22.2 No.0.5-1982 - Threaded Conduit Entries
- CSA C22.2 No. 94-M91 - Special Purpose Enclosures
- CSA C22.2 No. 14-13 - Industrial Control Equipment
- UL 50-12th Edition - Enclosures for Electric Equipment
- UL 508-17th Edition - Industrial Control Equipment